



Dr Vinod Tare
 Professor & Founding Head - cGanga

March 4, 2023

Shapoorji Pallonji And Company Pvt Ltd
 Nagindas Master Road, Fort Mumbai
 400001 Maharashtra India

Subject: Performance Assessment of Various STPs in Kanpur
Ref: IITK_LoI_01 dated: May 30, 2022

Shapoorji Pallonji and Company Pvt Ltd vide their order No IITK_LoI_01 dated: May 30, 2022 requested to carryout 24 hr composite sampling through collection of grab samples at 2 hr interval and analysis of various composite samples prepared by mixing grab samples in proportion to the measured flows at the inlet and outlet of 130 MLD STP (Jajmau Kanpur), 43 MLD STP (Jajmau Kanpur), 42 MLD STP (Sajari, Kanpur), and 210 MLD STP (Bingawan, Kanpur) for certain parameters.

The samples were collected by sampling team of cGanga, IIT Kanpur in presence of representatives from Shapoorji Pallonji and Co. Pvt Ltd and GPCU, UPJN during February 15-21, 2023.

The preservation and analysis of the samples were done as per the Standard Methods (Standard Methods for the Examination of Water and Wastewater, APHA). The analysis of the sample for the requested parameters started immediately after bringing it to laboratory. The results of the analysis are reported in following table.

Estimated Parameter Values of Various STPs in Kanpur

Location	Date of Sampling	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Fecal Coliform	Total Coliform
130 MLD, Jajmau (Inlet)	February 20-21, 2023	554	216	540	3.30E+07	2.80E+08
130 MLD, Jajmau (Outlet)	February 20-21, 2023	58	39	150	1.30E+06	2.20E+06
43 MLD, Jajmau (Outlet)	February 20-21, 2023	30	26	105	9.00E+05	1.70E+06
42 MLD, Sajari (Inlet)	February 17-18, 2023	454	180	450	3.00E+06	1.40E+07
42 MLD, Sajari (Outlet)	February 17-18, 2023	26	20	90	1.70E+02	3.30E+02
210 MLD, Bingawan (Inlet)	February 15-16, 2023	482	200	512	5.00E+07	5.00E+09
210 MLD, Bingawan (Outlet)	February 15-16, 2023	192	116	240	2.30E+05	8.00E+05

NOTE: The results presented are on basis of one-time analysis of the samples collected by cGanga, IIT Kanpur.

(Vinod Tare)