




8	Internal road, Landscaping work and Campus lighting work			1. Order renovation of IPS, jettobulbul road found settlement some location inside campus, that must be rectified by KRAMS. 2. Total light & box in working condition. 3. Safety of water connection for drinking and daily purpose. 4. Planting work of decorative tree required.		05.12.2023		Pending
9	Water Chamber	Bad Structure in unsatisfactory condition		Water maintenance and painting work should be done by KRAMS for NCC team.		05.12.2023		Pending
10	Bad Flow Condition	Bad flow of sewerage from Panning Tapping close Near a Sewerage from drainage house		1. KRAMS need to investigate the Bad flow condition.		05.12.2023		Pending
<div><div>STC</div><div>SITE INSPECTION OF JAUMAU ASSOCIATED IPS REPORT</div></div>						05.12.2023	Date 22.02.2023	1. Mr. Raju Kumar Singh, Support Engineer, Mechanical, STC, Kanpur. 2. Mr. Karan Virender Singh, Support Site Supervisor, STC, Kanpur.
S. No.	Assignment	Assessment of Current Condition	Assessment of Current Condition Photo	Current Defects and Corrective Action Suggested by STC, FE	Corrective Action Completed by KRAMS	Original Date of Issue	Proposed Date to Resolve by KRAMS	Current Status of Compliance
1	IPS work							
2	Drainage Nala Tapping	Un-Satisfactory Condition		During site visit it was found that there was no Overflow condition on 02.02.2023.		01.12.2023		Pending
3	Drainage Nala Tapping	Manual Cleaner bar screen Chamber		1. Gullies of open channel gullies didn't find KRAMS, need to be installed at the head of the gullies. 2. Manual empty for disposal material should be arranged by KRAMS. 3. Case of flow of gullies only 2 hrs in a working condition.		02.12.2023		Pending
4	Drainage Nala Tapping	Bad flow of sewerage from Panning Tapping		1. Observation of bad flow surface should be rectified by KRAMS. 2. Garbage material should be remove from campus. 3. Observation of boundary wall required. 4. Sewerage gullies should be rectified by KRAMS under landscaping work. 5. Bad gullies should be repair by KRAMS. 6. CCTV installation need to be done.		02.12.2023		Pending

