



PROJECT ENGINEER *for*

National Mission for Clean Ganga- Development, Rehabilitation with
Operation & Maintenance of STPs at Kanpur under Hybrid Annuity based PPP mode

Shah Technical Consultants Private Limited

ADDRESS :117/231 " O" Block Geeta Nagar Near Ram Lila Ground ,Kanpur-208025 Phone -05123571573 E-Mail : pe.kanpurstc@gmail.com

Ref STC / PE / KNP / 2182/Pankha

Date: 29/04/2024

To,
Superintending Engineer
Construction circle
Uttar Pradesh Jal Nigam
(Rural) Kanpur,UP.
Email: seupjknkp@gmail.com

Sub: HAM KANPUR: Deficiencies found in Joint inspection of 30 MLD STP Pankha

Dear Sir,

With reference to above noted subject kindly refer to joint inspection of 30 MLD STP Pankha on 26.04.24. Following deficiencies were observed which are listed below.

- SBR no 4 manually in operation. DI card is required for its automation.
- Supernatant sump agitator oil seal problem.
- Sludge thickner not functioning properly.
- Centrifuge pump 2 nos. are under maintenance.
- Poly dosing pump one no. under maintenance.
- Centrifuge 2 nos. not in operation.
- Analyser not working properly.

You are requested to kindly direct KRMPL to attend the deficiencies immediately.

Yours sincerely



(Anil Kumar Seth)
Team Leader, STC Kanpur

Copy to the following for information & necessary action:

1. Mr. Rajat Gupta, SWMS, NMCG, New Delhi
2. Ms. Nidhi Dwivedi, Project Officer – Technical, NMCG, New Delhi
3. Chief Engineer, Kanpur Zone, UP Jal Nigam, Kanpur.
4. PM-I, PM-E&M, GPCU, UP Jal Nigam, Kanpur.
5. Mr. P.C. Shukla, Concessionaire's Representative
6. Project Manager, Kanpur River Management Pvt. Ltd., Kanpur