

Inspection of 30 MLD STP Pankha dated 24/09/2024

The main points highlighted below.

PANKHA STP

- At MPS out of 5 pumps, all are operational due to fuse which needs to be replaced.
- SBR no: 4 is running now auto mode.
- Thickner is non operational. It is under maintenance. Gear repairing in progress (teeth damage).
- Out of 3 nos Sludge feed pump One no is non operational. Its shaft damaged.
- Out of 3 nos centrifuge one no non operational. It's shaft is jam.
- Out of 6 nos Blowers one is non operational, gear box assembly damaged.
- Canopy installations on motors are still pending. However material is available since long.
- Coupling problem in 1 no Organic Return Pump

ICI Nala (IPS)

- Out of 5 nos pump, 1 is non operational, motor binding is required.
- DG service pending.
- Canopy to be made over flow meter.

Sunder nagar Nala(IPS)

- Out of 5 no pumps all are operational.
- PGs are not working.
- Gate lighting pending

Diesel stock-

- STP- 830 lit
- ICI Nala- 398 lit
- Sundernagar-375 lit

Note-

- In ICI nalla 4 nos exhaust fan are to be installed.
- Compliance of Road restoration and other pending works have not been given by KRMPL and therefore they were not inspected. The work of road sinking near thermal nalla was in progress.
- Water supply problem in Sundarnagar IPS
- **Due to strike STP/IPS was not operational w.e.f. 23.09.24 and ICI IPS from 18.09.24 (flooding and strike)**