

Salient points of CSPS & Jajmau 130 MLD STP dated 07/04/25

CSPS Inspection Summary (07/04/25)

PUMPS

- **Total Pumps:** 7 Nos
 - **New Pumps:** 6 Nos
 - 4 Operational
 - 2 Under Repair
 - **Old Pump:** 1 No (Operational)

STARTERS

- **Total Starters:** 7 Nos
 - 6 Operational
 - Only 4 Pumps in use due to 2 pump issues
 - 7th (New) Starter Installed
 - **Connection to 7th pump pending** (as it is an old pump and cannot be connected to new starter)

MAIN PANELS

- **Old Panels:** 3 Nos
 - 1st Panel: Supplies to 3 Pumps
 - 2nd Panel: Supplies to 2 Pumps
 - 3rd Panel: Supplies to 2 Pumps
 - **New Panels:**
 - 1 Installed (Cabling to starters pending)
 - 2 Yet to be Installed
-

JAJMAU 130 MLD Status

1. **BFP**
 - Total: 4 Nos
 - Operational: 1 No only
2. **PST-2**
 - Non-operational
 - Materials being arranged; tank dewatering pending
3. **RSPH (Raw Sewage Pump House)**
 - Total: 4 Nos
 - Operational: 3 Nos
 - 4th pump pending due to NRV valve issue (Pending for over 1 year)

4. **Chlorine Supply & Consumption Records**

- **Not Properly Maintained**
- This is a **serious issue** and has been pointed out in multiple inspections by **STC, Jal Nigam, and NMCG**